

Official Laboratory Report

Report To: CITY OF CHARLEVOIX
210 STATE ST
CHARLEVOIX MI 49720

Sample ID: LJ27595
Work Order: 01000796_01

System Name/Owner:	CITY OF CHARLEVOIX	WSSN/Pool ID:	01330
Collection Address:	97 GRANT ST, CHARLEVOIX	Source:	TYPE I
Collected By:	SHELLY MAYER	Site Code:	TP100
Township/Well#/Section:	CHARLEVOIX/72	Collector:	Other
County:	Charlevoix	Date Collected:	10/06/2020 07:00
Sample Point:	TP100	Date Received:	10/07/2020 10:54
Water System:	Public System Surface Water	Purpose:	Routine Monitoring

Sample Comment LJ27595 **Field Reagent Blank was analyzed and acceptable per method requirements.**

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not detected	ng/L	2	10/12/2020		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not detected	ng/L	2	10/12/2020		EPA 537.1	756426-58-1d
ADONA	Not detected	ng/L	2	10/12/2020		EPA 537.1	919005-14-4e
HFPO-DA	Not detected	ng/L	2	10/12/2020	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2991-50-6
NMeFOSAA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2355-31-9
PFBS	Not detected	ng/L	2	10/12/2020	420	EPA 537.1	375-73-5
PFDA	Not detected	ng/L	2	10/12/2020		EPA 537.1	335-76-2
PFDoA	Not detected	ng/L	2	10/12/2020		EPA 537.1	307-55-1
PFHpA	Not detected	ng/L	2	10/12/2020		EPA 537.1	375-85-9
PFHxA	Not detected	ng/L	2	10/12/2020	400000	EPA 537.1	307-24-4
PFHxS	Not detected	ng/L	2	10/12/2020	51	EPA 537.1	355-46-4
PFNA	Not detected	ng/L	2	10/12/2020	6	EPA 537.1	375-95-1
PFOA	Not detected	ng/L	2	10/12/2020	8	EPA 537.1	335-67-1
PFOS	Not detected	ng/L	2	10/12/2020	16	EPA 537.1	1763-23-1
PFTA	Not detected	ng/L	2	10/12/2020		EPA 537.1	376-06-7
PFTTrDA	Not detected	ng/L	2	10/12/2020		EPA 537.1	72629-94-8
PFUnA	Not detected	ng/L	2	10/12/2020		EPA 537.1	2058-94-8

RL: Reporting Limit	mg/L: milligrams / Liter (ppm)	CFU: Colony Forming Unit
MCL: Maximum Contaminant Level	ng/L: nanograms / Liter (ppt)	CAS: Chemical Abstract Service
AL: Action Level	MPN: Most Probable Number	Laboratory Contact: Marlene Kane
Not Detected: Not detected at or above the reporting limit (RL)		